



PDC Laboratories, Inc.

PROFESSIONAL • DEPENDABLE • COMMITTED

May 21, 2016

Philip Harrison
Salt Fork CUSD #512
7087 North 600 East Road
Sidell, IL 61876

Dear Philip Harrison:

Please find enclosed the analytical results for the sample(s) the laboratory received on **5/10/16 9:40 am** and logged in under work order **6051339**. All testing is performed according to our current TNI certifications unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Vice President, John LaPayne with any feedback you have about your experience with our laboratory.

Sincerely,

Julia Rada
Drinking Water Project Manager
(309) 692-9688 x1724
jrada@pdclab.com





ANALYTICAL RESULTS

Sample: 6051339-01
Name: South Elementary - Fountain - Library Hall
Matrix: Drinking Water - Grab

Sampled: 05/08/16 15:00
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	59	ug/L		05/13/16 11:15	05/13/16 12:43	KMC	EPA 200.8
Lead	25	ug/L		05/13/16 11:15	05/13/16 12:43	KMC	EPA 200.8

Sample: 6051339-02
Name: South Elementary - Jr. High - Fountain Elem Gym
Matrix: Drinking Water - Grab

Sampled: 05/08/16 15:22
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	130	ug/L		05/13/16 11:15	05/13/16 12:45	KMC	EPA 200.8
Lead	1.3	ug/L		05/13/16 11:15	05/13/16 12:45	KMC	EPA 200.8

Sample: 6051339-03
Name: South Elementary - Jr. High - Fountain Cafe
Matrix: Drinking Water - Grab

Sampled: 05/08/16 15:09
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	72	ug/L		05/13/16 11:15	05/13/16 12:46	KMC	EPA 200.8
Lead	7.4	ug/L		05/13/16 11:15	05/13/16 12:46	KMC	EPA 200.8

Sample: 6051339-04
Name: South Elementary - Jr. High - Sink Kitchens
Matrix: Drinking Water - Grab

Sampled: 05/08/16 15:19
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	73	ug/L		05/13/16 11:15	05/13/16 12:48	KMC	EPA 200.8
Lead	11	ug/L		05/13/16 11:15	05/13/16 12:48	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 6051339-05
Name: South Elementary - Fountain by Restrooms
Matrix: Drinking Water - Grab

Sampled: 05/08/16 15:04
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	91	ug/L		05/13/16 11:15	05/13/16 12:49	KMC	EPA 200.8
Lead	4.2	ug/L		05/13/16 11:15	05/13/16 12:49	KMC	EPA 200.8

Sample: 6051339-06
Name: North High School - Fountain 1st Floor
Matrix: Drinking Water - Grab

Sampled: 05/08/16 15:50
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	36	ug/L		05/13/16 11:15	05/13/16 12:51	KMC	EPA 200.8
Lead	1.2	ug/L		05/13/16 11:15	05/13/16 12:51	KMC	EPA 200.8

Sample: 6051339-07
Name: North High School - Fountain 3rd Floor
Matrix: Drinking Water - Grab

Sampled: 05/08/16 15:54
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	58	ug/L		05/13/16 11:15	05/13/16 12:52	KMC	EPA 200.8
Lead	2.3	ug/L		05/13/16 11:15	05/13/16 12:52	KMC	EPA 200.8

Sample: 6051339-08
Name: North High School - Fountain Basement
Matrix: Drinking Water - Grab

Sampled: 05/08/16 15:57
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	160	ug/L		05/13/16 11:15	05/13/16 13:04	KMC	EPA 200.8
Lead	< 1.0	ug/L		05/13/16 11:15	05/13/16 13:04	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 6051339-09
Name: North Gym - Fountain East 1
Matrix: Drinking Water - Grab

Sampled: 05/08/16 16:04
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	51	ug/L		05/13/16 11:15	05/13/16 13:05	KMC	EPA 200.8
Lead	< 1.0	ug/L		05/13/16 11:15	05/13/16 13:05	KMC	EPA 200.8

Sample: 6051339-10
Name: North High School - Sink Kitchen
Matrix: Drinking Water - Grab

Sampled: 05/08/16 15:58
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	21	ug/L		05/13/16 11:15	05/13/16 13:07	KMC	EPA 200.8
Lead	2.5	ug/L		05/13/16 11:15	05/13/16 13:07	KMC	EPA 200.8

Sample: 6051339-11
Name: North Elementary - Fountain - K-3 RR
Matrix: Drinking Water - Grab

Sampled: 05/08/16 16:21
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	60	ug/L		05/13/16 11:15	05/13/16 13:08	KMC	EPA 200.8
Lead	< 1.0	ug/L		05/13/16 11:15	05/13/16 13:08	KMC	EPA 200.8

Sample: 6051339-12
Name: North Elementary - Fountain - Foyer RR
Matrix: Drinking Water - Grab

Sampled: 05/08/16 16:24
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	67	ug/L		05/13/16 11:15	05/13/16 13:10	KMC	EPA 200.8
Lead	< 1.0	ug/L		05/13/16 11:15	05/13/16 13:10	KMC	EPA 200.8



ANALYTICAL RESULTS

Sample: 6051339-13
Name: North Elementary - Fountain - 5th Gr
Matrix: Drinking Water - Grab

Sampled: 05/08/16 16:14
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	39	ug/L		05/13/16 11:15	05/13/16 13:11	KMC	EPA 200.8
Lead	1.2	ug/L		05/13/16 11:15	05/13/16 13:11	KMC	EPA 200.8

Sample: 6051339-14
Name: North Elementary - Fountain - Music/Library
Matrix: Drinking Water - Grab

Sampled: 05/08/16 16:19
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	70	ug/L		05/13/16 11:15	05/13/16 13:13	KMC	EPA 200.8
Lead	3.3	ug/L		05/13/16 11:15	05/13/16 13:13	KMC	EPA 200.8

Sample: 6051339-15
Name: North Elementary - Sink Cafe
Matrix: Drinking Water - Grab

Sampled: 05/08/16 16:29
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Copper	11	ug/L		05/13/16 11:15	05/13/16 13:14	KMC	EPA 200.8
Lead	< 1.0	ug/L		05/13/16 11:15	05/13/16 13:14	KMC	EPA 200.8

Sample: 6051339-16
Name: South Elementary - Fountain - Library Hall
Matrix: Drinking Water - Grab

Sampled: 05/09/16 08:39
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Anions - PIA							
Nitrate-N	< 0.02	mg/L		05/10/16 14:47	05/10/16 14:47	SCR	EPA 300.0
Microbiology - PIA							
E. coli	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Opinion (Coliform)	Satisfactory			05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Total coliform bacteria	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*



ANALYTICAL RESULTS

Sample: 6051339-17
Name: South Elementary - Jr. High - Fountain Elem Gym
Matrix: Drinking Water - Grab

Sampled: 05/09/16 08:53
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<u>Anions - PIA</u>							
Nitrate-N	0.06	mg/L		05/10/16 16:33	05/10/16 16:33	SCR	EPA 300.0
<u>Microbiology - PIA</u>							
E. coli	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Opinion (Coliform)	Satisfactory			05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Total coliform bacteria	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*

Sample: 6051339-18
Name: South Elementary - Jr. High - Fountain Cafe
Matrix: Drinking Water - Grab

Sampled: 05/09/16 08:45
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<u>Anions - PIA</u>							
Nitrate-N	< 0.02	mg/L		05/10/16 17:08	05/10/16 17:08	SCR	EPA 300.0
<u>Microbiology - PIA</u>							
E. coli	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Opinion (Coliform)	Satisfactory			05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Total coliform bacteria	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*

Sample: 6051339-19
Name: South Elementary - Jr. High - Sink Kitchens
Matrix: Drinking Water - Grab

Sampled: 05/09/16 08:49
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<u>Anions - PIA</u>							
Nitrate-N	0.05	mg/L		05/10/16 17:43	05/10/16 17:43	SCR	EPA 300.0
<u>Microbiology - PIA</u>							
E. coli	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Opinion (Coliform)	Satisfactory			05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Total coliform bacteria	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*



ANALYTICAL RESULTS

Sample: 6051339-20
Name: South Elementary - Fountain by Restrooms
Matrix: Drinking Water - Grab

Sampled: 05/09/16 08:41
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Anions - PIA							
Nitrate-N	0.06	mg/L		05/10/16 18:19	05/10/16 18:19	SCR	EPA 300.0
Microbiology - PIA							
E. coli	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Opinion (Coliform)	Satisfactory			05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Total coliform bacteria	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*

Sample: 6051339-21
Name: North High School - Fountain 1st Floor
Matrix: Drinking Water - Grab

Sampled: 05/09/16 09:30
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Anions - PIA							
Nitrate-N	9.2	mg/L		05/10/16 19:47	05/10/16 19:47	SCR	EPA 300.0
Microbiology - PIA							
E. coli	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Opinion (Coliform)	Satisfactory			05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Total coliform bacteria	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*

Sample: 6051339-22
Name: North High School - Fountain 3rd Floor
Matrix: Drinking Water - Grab

Sampled: 05/09/16 09:34
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Anions - PIA							
Nitrate-N	9.2	mg/L		05/10/16 20:22	05/10/16 20:22	SCR	EPA 300.0
Microbiology - PIA							
E. coli	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Opinion (Coliform)	Satisfactory			05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Total coliform bacteria	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*



ANALYTICAL RESULTS

Sample: 6051339-23
Name: North High School - Fountain Basement
Matrix: Drinking Water - Grab

Sampled: 05/09/16 09:37
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Anions - PIA							
Nitrate-N	8.7	mg/L		05/10/16 20:57	05/10/16 20:57	SCR	EPA 300.0
Microbiology - PIA							
E. coli	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Opinion (Coliform)	Satisfactory			05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Total coliform bacteria	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*

Sample: 6051339-24
Name: North Gym - Fountain East 1
Matrix: Drinking Water - Grab

Sampled: 05/09/16 09:46
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Anions - PIA							
Nitrate-N	9.0	mg/L		05/10/16 21:33	05/10/16 21:33	SCR	EPA 300.0
Microbiology - PIA							
E. coli	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Opinion (Coliform)	Satisfactory			05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Total coliform bacteria	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*

Sample: 6051339-25
Name: North High School - Sink Kitchen
Matrix: Drinking Water - Grab

Sampled: 05/09/16 09:40
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Anions - PIA							
Nitrate-N	9.8	mg/L	Q4	05/10/16 23:18	05/10/16 23:18	SCR	EPA 300.0
Microbiology - PIA							
E. coli	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Opinion (Coliform)	Satisfactory			05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Total coliform bacteria	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*



ANALYTICAL RESULTS

Sample: 6051339-26
Name: North Elementary - Fountain - K-3 RR
Matrix: Drinking Water - Grab

Sampled: 05/09/16 10:00
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<u>Anions - PIA</u>							
Nitrate-N	9.7	mg/L		05/10/16 23:55	05/10/16 23:55	SCR	EPA 300.0
<u>Microbiology - PIA</u>							
E. coli	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Opinion (Coliform)	Satisfactory			05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Total coliform bacteria	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*

Sample: 6051339-27
Name: North Elementary - Fountain - Foyer RR
Matrix: Drinking Water - Grab

Sampled: 05/09/16 09:58
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<u>Anions - PIA</u>							
Nitrate-N	9.9	mg/L		05/11/16 00:32	05/11/16 00:32	SCR	EPA 300.0
<u>Microbiology - PIA</u>							
E. coli	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Opinion (Coliform)	Satisfactory			05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Total coliform bacteria	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*

Sample: 6051339-28
Name: North Elementary - Fountain - 5th Gr
Matrix: Drinking Water - Grab

Sampled: 05/09/16 10:05
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<u>Anions - PIA</u>							
Nitrate-N	9.0	mg/L		05/11/16 01:09	05/11/16 01:09	SCR	EPA 300.0
<u>Microbiology - PIA</u>							
E. coli	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Opinion (Coliform)	Satisfactory			05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Total coliform bacteria	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*



ANALYTICAL RESULTS

Sample: 6051339-29
Name: North Elementary - Fountain - Music/Library
Matrix: Drinking Water - Grab

Sampled: 05/09/16 10:02
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<u>Anions - PIA</u>							
Nitrate-N	8.5	mg/L		05/11/16 01:46	05/11/16 01:46	SCR	EPA 300.0
<u>Microbiology - PIA</u>							
E. coli	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Opinion (Coliform)	Satisfactory			05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Total coliform bacteria	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*

Sample: 6051339-30
Name: North Elementary - Sink Cafe
Matrix: Drinking Water - Grab

Sampled: 05/09/16 10:08
Received: 05/10/16 09:40

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<u>Anions - PIA</u>							
Nitrate-N	9.5	mg/L		05/11/16 02:59	05/11/16 02:59	SCR	EPA 300.0
<u>Microbiology - PIA</u>							
E. coli	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Opinion (Coliform)	Satisfactory			05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*
Total coliform bacteria	Absent		A	05/10/16 10:32	05/11/16 07:45	HAW	SM 9223B*



NOTES

Specific method revisions used for analysis are available upon request.

Certifications

PIA - Peoria, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553
Missouri Department of Natural Resources Certificate of Approval for Microbiological Laboratory Service No. 870
Drinking Water Certifications: Iowa (240); Kansas (E-10338); Missouri (870)
Wastewater Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)
Hazardous/Solid Waste Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO

USEPA DMR-QA Program

STL - St. Louis, MO

TNI Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS Lab No. E-10389
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171050
Drinking Water Certifications: Missouri (1050)
Missouri Department of Natural Resources

* Not a TNI accredited analyte

Qualifiers

- A Absent
- Q4 The matrix spike recovery result is unusable since the analyte concentration in the sample is greater than four times the spike level. The associated blank spike was acceptable.

Certified by: Julia Rada, Drinking Water Project Manager



BLUE
PDC Laboratories, Inc.
 2231 W. Altorfer Dr
 Peoria, IL 61615

CHAIN OF CUSTODY RECORD
 State where samples were collected IL

Phone: (800) 752-6651
 Fax: (309) 692-9689
 www.pdclab.com

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

CLIENT	P.O. NUMBER	PROJECT NAME	DATE SHIPPED	ANALYSIS REQUESTED	WORK ORDER (FOR LAB USE ONLY)
1 SALT FORK CUSD #512				3	4
ADDRESS: 7087 NORTH 600 E RD.					
CITY: SIDELL	STATE: IL	ZIP: 61876	SAMPLER (PLEASE PRINT): PHIL T. HARRISON		LOGIN #: 6051335-30
CONTACT PERSON: PHIL HARRISON					LOGGED BY:
SIGNATURE:					PROJECT: _____
SIGNATURE:					PROJ MGR: _____
2					
South Elem Fountain Lib Hall	S-8-16	15:00	X	X	
South Elem/Irth Fountain Elem Gym	S-8-16	15:22	X	X	
South Elem/Irth Fountain Cafe	S-8-16	15:09	X	X	
South Elem/Irth Sink Kitchen	S-8-16	15:19	X	X	
South Elem Fountain by Restrooms	S-8-16	15:04	X	X	
North High School Fountain - 1 st Fl	S-8-16	15:50	X	X	
North High School Fountain - 3 rd Fl	S-8-16	15:54	X	X	
North High School Fountain - Box	S-8-16	15:57	X	X	
North Gym Fountain East 4	S-8-16	16:04	X	X	
North Gym Fountain East 4			X	X	
6					
5 TURNAROUND TIME REQUESTED (RUSH FEE IS SUBJECT TO APPROVAL AND SURCHARGE)	<input checked="" type="checkbox"/> NORMAL	<input type="checkbox"/> RUSH	DATE RESULTS NEEDED	6	
7	RECEIVED BY (SIGNATURE):	DATE: 8-9-16	TIME: 10:10	RECEIVED BY (SIGNATURE):	DATE: 8-12-16
	RECEIVED BY (SIGNATURE):	DATE:	TIME:	RECEIVED BY (SIGNATURE):	DATE:
	RECEIVED BY (SIGNATURE):	DATE:	TIME:	RECEIVED BY (SIGNATURE):	DATE:
8					
COMMENTS (FOR LAB USE ONLY)					
SAMPLE TEMPERATURE UPON RECEIPT				20°C	
CHILL PROCESS STARTED PRIOR TO RECEIPT				YORKIN	
SAMPLE(S) RECEIVED ON ICE				YORKIN	
PROPER BOTTLES RECEIVED IN GOOD CONDITION				YORKIN	
BOTTLES FILLED WITH ADEQUATE VOLUME				YORKIN	
SAMPLES RECEIVED WITHIN HOLD TIME(S)				YORKIN	
(EXCLUDES TYPICAL FIELD PARAMETERS)				YORKIN	
DATE AND TIME TAKEN FROM SAMPLE BOTTLE				YORKIN	

Blue

PDC Laboratories, Inc. CAP
2231 W. Altorfer Dr
Peoria, IL 61615

CHAIN OF CUSTODY RECORD
State where samples were collected IL

Phone: (800) 752-6651
Fax: (309) 692-9689
www.pdcclab.com

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT SALT FORK CUSD #512 ADDRESS: 7089 North 600 East Rd CITY: Sibley STATE: IL ZIP: 61876 CONTACT PERSON: PHIL HARRISON SIGNATURE: <i>[Signature]</i>		P.O. NUMBER PROJECT NAME EMAIL PHONE		DATE SHIPPED MEANS SHIPPED MATRIX TYPES: WW - WASTE WATER DW - DRINKING WATER GW - GROUND WATER WWSL - SLUDGE MAS - SOLID LCHT - LEACHATE OTHER:		3 ANALYSIS REQUESTED 4 LEAD AND COPPER 5 COLIFORM P/A 6 NITRATE		WORK ORDER (FOR LAB USE ONLY) 4 LOGIN #: LOGGED BY: PROJECT: PROJ MGR:		REMARKS			
2 SAMPLES RECEIVED DATE RECEIVED TIME RECEIVED SIGNATURE		DATE RECEIVED TIME RECEIVED SIGNATURE		DATE RECEIVED TIME RECEIVED SIGNATURE		DATE RECEIVED TIME RECEIVED SIGNATURE		DATE RECEIVED TIME RECEIVED SIGNATURE		DATE RECEIVED TIME RECEIVED SIGNATURE			
North High School Sink Kitchen S-8-16 15:58 <i>[Signature]</i>		North Elem Fountain K-3 RR S-8-16 16:21 <i>[Signature]</i>		North Elem Fountain Foster RR S-8-16 16:24 <i>[Signature]</i>		North Elem Fountain 5th CR S-8-16 16:14 <i>[Signature]</i>		North Elem Fountain Mus/LIB S-8-16 16:19 <i>[Signature]</i>		North Elem Sink Cafe S-8-16 16:29 <i>[Signature]</i>		DATE RECEIVED TIME RECEIVED SIGNATURE	
5 TURNAROUND TIME REQUESTED (RUSH TAT IS SUBJECT TO APPROVAL AND SURCHARGE) <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH		6 DATE RESULTS NEEDED		7 RECEIVED BY (SIGNATURE) DATE: 5-9-16 TIME: 10:10 <i>[Signature]</i>		RECEIVED BY (SIGNATURE) DATE: TIME: <i>[Signature]</i>		RECEIVED BY (SIGNATURE) DATE: TIME: <i>[Signature]</i>		RECEIVED BY (SIGNATURE) DATE: TIME: <i>[Signature]</i>		8 COMMENTS (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT: 20 °C CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE PROPER BOTTLES RECEIVED IN GOOD CONDITION BOTTLES FILLED WITH ADEQUATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIME(S) (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE	

WHITE
CAP
PO
PIPES

PDC Laboratories, Inc.
2231 W. Altorfer Dr
Peoria, IL 61615

CHAIN OF CUSTODY RECORD
State where samples were collected IL

Phone: (800) 752-6651
Fax: (309) 692-9689
www.pdcilab.com

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

CLIENT	P.O. NUMBER	PHONE	PROJECT NAME	DATE SHIPPED	ANALYSIS REQUESTED	WORK ORDER (FOR LAB USE ONLY)
1 SALT FORK CUSD #512						4
ADDRESS: 7089 NORTH 600 EAST RD.						
CITY: SIDELL	STATE: IL	ZIP: 61876	SAMPLER (PLEASE PRINT): PHILIP T. HARRISON	MEANS SHIPPED:		
CONTACT PERSON: PHILIP HARRISON			SAMPLER'S SIGNATURE: <i>[Signature]</i>	MATRIX TYPES: WW - WASTE WATER DW - DRINKING WATER GW - GROUND WATER WSL - SLUDGE NAS - SOLID LCM - LEACHATE OTHER:		
SAMPLE DESCRIPTION AS YOU WANT TO REPORT		DATE COLLECTED	TIME COLLECTED	SAMPLE WITH GRAD	MATRIX TYPE	BOTTLE COUNT
South Elem Fountain Lib Hall	5-9-16	08:39	X		DW	3
South Elem/Jr Hi Fountain Elem Gym	5-9-16	08:53	X		DW	3
South Elem/Jr Hi Fountain Cafe	5-9-16	08:45	X		DW	3
South Elem/Jr Hi Sink Kitchen	5-9-16	08:49	X		DW	3
South Elem Fountain by Restrooms	5-9-16	08:41	X		DW	3
North High School Fountain - 1 st Fl	5-9-16	09:30	X		DW	3
North High School Fountain - 3 rd Fl	5-9-16	09:34	X		DW	3
North High School Fountain - Box	5-9-16	09:37	X		DW	3
North Gym Fountain East 1	5-9-16	9:46	X		DW	3
North Gym Fountain East 2						
5 TURNAROUND TIME REQUESTED (RUSH TAT IS SUBJECT TO APPROVAL AND SURCHARGE)	<input checked="" type="checkbox"/> NORMAL	<input type="checkbox"/> RUSH	DATE RESULTS NEEDED	6	The sample temperature will be measured upon receipt at the lab. By including this area, you request that we notify you before proceeding with analysis. If the sample temperature is outside of the range of 0-15.0°C. By not including this area, you allow the lab to proceed with analytical testing regardless of the sample temperature.	
7 RELINQUISHED BY (SIGNATURE): <i>[Signature]</i>	DATE: 5-9-16	TIME: 10:10	RECEIVED BY (SIGNATURE): <i>[Signature]</i>	DATE: 5-10-16	TIME: 9:30	8 COMMENTS (FOR LAB USE ONLY)
RELINQUISHED BY (SIGNATURE):	DATE:	TIME:	RECEIVED BY (SIGNATURE):	DATE:	TIME:	SAMPLE TEMPERATURE UPON RECEIPT: 20 °C CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE PROPER BOTTLES RECEIVED IN GOOD CONDITION BOTTLES FILLED WITH ADEQUATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIME(S) (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE
RELINQUISHED BY (SIGNATURE):	DATE:	TIME:	RECEIVED BY (SIGNATURE):	DATE:	TIME:	

WHITE
CAP
NO LINES

PDC Laboratories, Inc.
2231 W. Altorfer Dr
Peoria, IL 61615

CHAIN OF CUSTODY RECORD

State where samples were collected IL

Phone: (800) 752-6651
Fax: (309) 692-9689
www.pdcclab.com

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

CLIENT	P.O. NUMBER	PROJECT NAME	DATE SHIPPED	ANALYSIS REQUESTED	WORK ORDER (FOR LAB USE ONLY)
1 SALT FORK CUSD #512				3 LEAD AND COPPER COLIFORM P/A NITRATE	4
ADDRESS: 7087 NORTH 600 EAST RD	PHONE	EMAIL	MEANS SHIPPED		LOGIN #:
CITY: SIDELL STATE: IL ZIP: 61876	SAMPLER (PLEASE PRINT)		MATRIX TYPES: WW - WASTE WATER DW - DRINKING WATER GW - GROUND WATER WWSL - SLUDGE MAS - SOLID LCHT - LEACHATE OTHER:		LOGGED BY:
CONTACT PERSON: PHIL HARRISON	SAMPLER SIGNATURE: <i>Phil Harrison</i>				PROJECT:
2					PROJ MGR:
North High School Sink Kitchen	05-09-16 09:40	X	DW	X	REMARKS
North Elem Fountain K-3 RB	5-9-16 10:00	X	DW	X	
North Elem Fountain Foyer RR	05-09-16 09:59	X	DW	X	
North Elem Fountain 5th GR	5-9-16 10:05	X	DW	X	
North Elem Fountain Mus/LIB	5-9-16 10:02	X	DW	X	
North Elem Sink Cafe	5-9-16 10:08	X	DW	X	
		X	DW	X	
		X	DW	X	
		X	DW	X	
		X	DW	X	
		X	DW	X	
		X	DW	X	
		X	DW	X	
5 TURNAROUND TIME REQUESTED (RUSH FEE IS SUBJECT TO APPROVAL AND SURCHARGE)	NORMAL <input type="checkbox"/> RUSH <input type="checkbox"/>	DATE RESULTS NEEDED	6	The sample temperature will be measured upon receipt at the lab. By initiating this area, you request that we notify you before proceeding with analysis if the sample temperature is outside of the range of 0-10°C. By not initiating this area, you allow the lab to proceed with analytical testing regardless of the sample temperature.	
7 RECEIVED BY (SIGNATURE) <i>Phil Harrison</i>	DATE: 5-9-16 TIME: 10:10	RECEIVED BY (SIGNATURE)	DATE: TIME:	B COMMENTS (FOR LAB USE ONLY)	
REINQUIRED BY (SIGNATURE)	DATE: TIME:	RECEIVED BY (SIGNATURE)	DATE: TIME:	SAMPLE TEMPERATURE UPON RECEIPT	
REINQUIRED BY (SIGNATURE)	DATE: TIME:	RECEIVED BY (SIGNATURE)	DATE: TIME:	CHILL PROCESS STARTED PRIOR TO RECEIPT	
				SAMPLE(S) RECEIVED ON ICE	
				PROPER BOTTLES RECEIVED IN GOOD CONDITION	
				BOTTLES FILLED WITH ADEQUATE VOLUME	
				SAMPLES RECEIVED WITHIN HOLD TIME(S)	
				(EXCLUDES TYPICAL FIELD PARAMETERS)	
				DATE AND TIME TAKEN FROM SAMPLE BOTTLE	

Phone: (800) 752-6651
 Fax: (309) 692-9689
 www.pdcilab.com

CHAIN OF CUSTODY RECORD
 State where samples were collected IL

PDC Laboratories, Inc. WATH
 2231 W. Aitorfer Dr UNES
 Peoria, IL 61615

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

CLIENT	P.O. NUMBER	PROJECT NAME	DATE SHIPPED	ANALYSIS REQUESTED	WORK ORDER (FOR LAB USE ONLY)
1 SALT FORK CUSD #512				3 LEAD AND COPPER 4 COLIFORM PA 5 NITRATE	4
ADDRESS 7089 NORTH 600 EAST RD.	PHONE	EMAIL	MEANS SHIPPED		LOGIN #
CITY SIDELL	SAMPLER (PLEASE PRINT) PHILIP T. HARRISON		MATRIX TYPES: WW - WASTE WATER DW - DRINKING WATER GW - GROUND WATER WWSL - SLUDGE NAS - SOLID LCHT - LEAK-HATE OTHER:		LOGGED BY:
STATE IL	SAMPLER'S SIGNATURE <i>[Signature]</i>				PROJECT:
ZIP 61876					PROJ MGR:
CONTACT PERSON PHILIP HARRISON					REMARKS
2	DATE COLLECTED	TIME COLLECTED	DATE RESULTS NEEDED	DATE	TIME
South Elem Fountain Lib Hall	5-9-16	08:39	<input type="checkbox"/>	DW	3
South Elem/IrHi Fountain Elem Gym	5-9-16	08:53	<input type="checkbox"/>	DW	3
South Elem/IrHi Fountain Cafe	5-9-16	08:45	<input type="checkbox"/>	DW	3
South Elem/IrHi Sink Kitchen	5-9-16	08:49	<input type="checkbox"/>	DW	3
South Elem Fountain by Restrooms	5-9-16	08:41	<input type="checkbox"/>	DW	3
North High School Fountain - 1 st Fl	5-9-16	09:30	<input type="checkbox"/>	DW	3
North High School Fountain - 3 rd Fl	5-9-16	09:34	<input type="checkbox"/>	DW	3
North High School Fountain - Box	5-9-16	09:37	<input type="checkbox"/>	DW	3
North Gym Fountain East 1	5-9-16	9:46	<input type="checkbox"/>	DW	3
North Gym Fountain East 2			<input type="checkbox"/>	DW	3
5 TURNAROUND TIME REQUESTED (RUSH FEE IS SUBJECT TO APPROVAL AND SURCHARGE)	<input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	DATE RESULTS NEEDED	DATE	TIME	6
7 RELINQUISHED BY (SIGNATURE) <i>[Signature]</i>	DATE 5-9-16	TIME 10:10	RECEIVED BY (SIGNATURE) <i>[Signature]</i>	DATE	TIME
RELINQUISHED BY (SIGNATURE) <i>[Signature]</i>	DATE	TIME	RECEIVED BY (SIGNATURE) <i>[Signature]</i>	DATE	TIME
RELINQUISHED BY (SIGNATURE) <i>[Signature]</i>	DATE	TIME	RECEIVED BY (SIGNATURE) <i>[Signature]</i>	DATE	TIME
8	COMMENTS (FOR LAB USE ONLY)				
	SAMPLE TEMPERATURE UPON RECEIPT CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE PROPER BOTTLES RECEIVED IN GOOD CONDITION BOTTLES FILLED WITH ADEQUATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIME(S) (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE				
	20°C Y. COLI Y. COLI Y. COLI Y. COLI Y. COLI				

PDC Laboratories, Inc.
 2231 W. Altorfer Dr
 Peoria, IL 61615

BOTTLE
 WITH
 LINES

CHAIN OF CUSTODY RECORD

State where samples were collected IL

Phone: (800) 752-6651
 Fax: (309) 692-9689
 www.pdcclab.com

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT: SALT FORK CUSD #512 ADDRESS: 7087 North 600 East Rd. CITY: SIDELL STATE: IL ZIP: 62716 CONTACT PERSON: PHIL HARRISON PHONE: _____ EMAIL: _____ PROJECT NAME: _____ DATE SHIPPED: _____ MEANS SHIPPED: _____ MATRIX TYPES: _____ WW - WASTE WATER DW - DRINKING WATER GW - GROUND WATER WWSL - SLUDGE MAS - SOLID LCHT - LEACHATE OTHER: _____		3 ANALYSIS REQUESTED: LEAD AND COPPER COLIFORM P/A NITRATE		4 WORK ORDER (FOR LAB USE ONLY) LOGIN #: _____ LOGGED BY: _____ PROJECT: _____ PROJ MGR: _____ REMARKS: _____	
2 SAMPLE DESCRIPTION AS YOU WOULD REPORT IT DATE COLLECTED TIME COLLECTED SAMPLE TYPE MATRIX TYPE BOTTLE TYPE North High School Sink Kitchen 5-9-16 09:40 X DW 3 North Flem Fountain K-3 RB 5-9-16 16:00 X DW 3 North Flem Fountain Foyer RR 5-9-16 09:58 X DW 3 North Flem Fountain 5th Gr 5-9-16 10:05 X DW 3 North Flem Fountain Mus/Lib 5-9-16 10:02 X DW 3 North Flem Sink Cafe 5-9-16 16:08 X DW 3		6 DATE RESULTS NEEDED <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH		5 TURNAROUND TIME REQUESTED (RUSH FEE IS SUBJECT TO APPROVAL AND SURCHARGE) <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	
7 RECEIVED BY (SIGNATURE) DATE TIME RECEIVED BY (SIGNATURE) 5-9-16 10:10 RECEIVED BY (SIGNATURE) _____ RECEIVED BY (SIGNATURE) _____		8 COMMENTS (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT: 20 °C CHILL PROCESS STARTED PRIOR TO RECEIPT SAMPLE(S) RECEIVED ON ICE BOTTLES FILLED WITH ADEQUATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIME(S) (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE		(Additional signature area)	